P.O.Box**886**k18631

Greensboro, NC 27419 (919) 668-4821

JAN. 7 1991

Winston-Salem Regional Office

January 4, 1991

Tom Salley NCDEHNR 8025 North Point Blvd. Suite 100 Winston-Salem, NC 27106

Re: UST removal, Piedmont Triad Airport - Fire Station

Greensboro, Guilford County

Dear Mr. Salley;

On December 11, 1990 we removed one 550 gallon #2 heating oil tank from the above location. This work was part of other UST work done the week of November 11 at an old service station on airport property.

One soil sample was collected 2 feet below tank grade at a depth of 8 feet below surface grade. The sample was collected from the floor of the excavation. The tank was buried 2 feet below surface grade.

The sample was collected on December 13 at 11:40 am. It was taken to the lab immediately and delivered there at 11:50 am. The sample was collected from dirt dug up with our backhoe.

Attached is the site map, soil sample result, and the chain of custody form for the sample. The hole has been backfilled. If you need anything further, please let me know.

Sincerely,

Thad Chesson

Chris Colenda, Southern Mapping and Engineering

Terry Cole, Guilford County Public Health

December 21, 1990

A.G. Dept. NAUD

AAM 7 1991

Winston-Salem Regional Office

REPORT OF ANALYSIS

JOB #:

PES01213

CUSTOMER: Piedmont Environmental

ATTN: Thad Chesson

P.O.#: Airport Fire Station

SAMPLE: # 5269 550 GAL #2 HEATING DIL NORTH

RESULTS

5269

Total Petroleum Hydrocarbon

(ppm)

(10

by Method 3550

Guilford Laboratopies, Inc.

GUILFORD LABORATORIES

| 250 | site: finding + Triad Armot (Fire Station) 5 = Soil |
|---|---|
| sampling Date: 12/2/2/20 (p/(a)) sample Description | ner Preservation |
| 550 gallon # 6 hanting of | |
| | |
| | |
| | |
| | |
| Relinquished by: | Time :50 |
| Recieved by : | Date: /2//3/95 Time 4:50 (p/(a)) |
| Relinquished by : | Date:/ Time:(p / a) |
| Recieved by : | Date:/ Time: (p / a) |
| Relinquished by : | Date:/ Time: (p / a) |
| Recieved by : | Date:/ Time: (p / a) |
| Relinquished by : | ; (p / |
| Recieved by : | |
| Guilford Labs Phone | Phone: 919-854-2320 |

